

**REVISED 10-3-2023**

### **Tab 17 Phase I Environmental Review / Environmental Test Results**

A Phase I Environmental Site Assessment prepared in accordance with **ASTM E-1527-21** and the Agency requirements found in the Submission Guide for Architects (list of non-scope items to be investigated by the Environmental Consultant), is required for **ALL** developments. Existing buildings scheduled for rehabilitation or demolition shall be investigated for environmental hazards. **The report cannot be more than 24 months old at the time the Application is submitted. An updated report provided by the original report's environmental consultant may be provided when the original report is between 24 and 36 months old at the time the Application is submitted. Only the executive summary of the Phase I report shall be submitted in the Application.** The update report from the environmental consultant must certify that the five (5) actions listed as items (i-v) under section 4.6 *Continued Viability of Environmental Site Assessment* of the **ASTM E 1527-21** Environmental Site Assessment Standard have been met. Only the executive summary of the report should be submitted in the Application, which shall indicate if remediation or further testing is required and include a cost estimate for remediation. The report shall also be accompanied by a certification from the applicant stating that any issues raised in the environmental review have been reviewed and budgeted accordingly in the development budget. The applicant must provide a breakdown of related costs and identify where this cost is included in the development budget. If the executive summary indicates there are no environmental issues, a certification is not necessary.

For existing buildings scheduled for rehabilitation, the Phase I report must also include testing for the following hazards: lead in water, lead-based paint, asbestos and radon. For existing buildings scheduled to be demolished as part of the project, only testing for asbestos is required. For preservation developments, please refer to the testing requirements on the following page.

**Lead in Water:** At least one (1) test for lead in the domestic water shall be performed in each building within the development. In buildings larger than 10,000 total square feet, at least two (2) tests shall be performed. Each test shall consist of two samples; an initial draw sample taken after a period of no water use, and a second sample taken after thoroughly flushing the system. Samples shall be taken as far as possible from the water service entrance to the building. In a rehabilitation development, if all water lines within the building and all lines out to the public water main are scheduled for replacement as part of the project, testing for lead in the water is not required.

**Lead Based Paint:** Paint throughout any building(s) built prior to 1978 shall be analyzed for lead content using an x-ray fluorescence (XRF) spectrum analyzer performed in accordance with HUD's "Final Rule", 24 CFR Part 35, as amended June 21, 2004.

**Asbestos:** A survey of any building(s) constructed prior to 1978 shall be performed to identify suspect asbestos containing materials. All such materials shall be tested using polarized light microscopy (PLM).

**Radon:** Radon testing shall be performed on the lowest floor level of each building in the development, at a rate of one test for every 2,000 square feet of basement/ground floor area. In addition, a test shall be performed in each stair tower and elevator shaft that will remain in use after the rehabilitation.

All environmental sampling shall be performed by certified personnel and all testing shall be done by an accredited testing laboratory. All test results that are above the “action level” shall be clearly identified.

**Preservation development applicants should also refer to Tab 34 “Project Capital Needs Assessment” for testing requirements. Preservation developments are required to follow the Tab 34 testing requirements and not the Tab 17 requirements.**

All Low-Income Tax Credit applicants must follow the Environmental Remediation Monitoring Program found at Section 1.24 of the Submission Guide for Architects.